

Notified body No. 1121
Warrington Certification Limited, Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK

Certificate of constancy of performance

1121-CPR-AG0173

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Santos 768EQ, 770EQ, 772EQ, 785EQ, 788EQ, 790EQ & 792EQ Mortice Sashlocks

Intended use: For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Harmonised technical specification
	Mechanical test evidence: 179908 Fire Test Evidence: 157831	
Self closing 5.4.2 Closing force 5.1.2 Re-latching force of latch bolt	Grade 8 = 200kg door mass with 15N maximum closing force >2.5N	EN 12209: 2003 / AC 2005
Durability of self closing 5.3.1 Durability of latch action	Grade M = 200,000 cycles with 25N side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire	Grade 1	
Control of Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

Certificate of constancy of performance

1121-CPR-AG0173

Produced for

**Manufacturas Santos, S.A.
Raso de Alagoa
AP 19
3754-909 Águeda
Portugal**

and produced in the manufacturing plant

W/001

This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 12209:2003/AC 2005

under system 1 of AVCP are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on **06/05/15** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Paul Duggan
Certification Manager
Warrington Certification Ltd

