



Certificate number: 2106726

Date issued 9th June 2021

Date expired 8th June 2026 Original/Amendment *Amendment*

Kiwa UK Regulation 4 (KUKreg4) Approval

ATS3 – Without Production Surveillance

Issued by Kiwa Watertec (UK)

Evaluation Guideline: Kiwa UK – EG004
Reference Standards: Regulators Specification
Model Designations: see Appendix

Factor: D Line.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied on to comply with the above Evaluation Guideline and Standards, and can be marked with the KUKreg4mark.

The intended use of this certificate is for compliance with Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales; 2009 Northern Ireland and 2014 Byelaws Scotland

This certificate has been issued in accordance with the Kiwa regulations for product certification

Signed on behalf of Kiwa Watertec

David Jay,
Business Unit Manager – Authorised Signatory
Kiwa Watertec

CERTIFICATE

390177301

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate issued to:
D Line
Roskildevej 22
2620 Albertslund
Denmark



UK Approval Certificate (page 2 of 2)

Appendix to Certificate 2106726

The following products are covered by this certificate -

<p>PRODUCT DESCRIPTION Range of wall mounted concealed manual blending valves with a brass body and ceramic cartridge headwork which control the flow and mixes the hot and cold water. Model QS3200 includes a diverter cartridge. Model QS3400 is a spout connector to be used in conjunction with models listed in this approval. ATS3 – Without Production Surveillance.</p>
<p>MODEL(S) QS3100 (single outlet) QS3200 ((two outlet) QS3400 (spout connector) QT3100 (single outlet)</p>
<p>SIZE: 1/2" BSP(F).</p>
<p>SCOPE: Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature 60°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 60°C. Wall Mounted.</p>
<p>MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.</p>
<p>BACKFLOW PROTECTION NOTES Consider balanced supplies or appropriate backflow protection at the inlets. Consideration must be made on installation to the airgap arrangement.</p>
<p>MARKING QT00 logo on EPDM sheet.</p>
<p>ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.</p>

Extra Notes