



Certificate number: 2304705 (1)

Issued 13/04/2023

Expires 13/04/2028

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

D Line.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:

D Line
ROSKILDEVEJ 22
2620 ALBERTSLUND
Denmark



KUKreg4

Product Certificate

Appendix to Certificate number: 2304705

The following products belong to this certificate

PRODUCT DESCRIPTION Range of wall mounted infrared sensor taps with a premix control unit and a stainless steel spout outlet. ATS3 – Without Production Surveillance.
MODEL(S) QST3190xxx Infrared wall sensor tap 190mm. QST3290xxx Infrared wall sensor tap 250mm.
SIZE: ½" BSP(M).
SCOPE: Manufacturer recommended maximum working pressure 8 Bar & maximum operating temperature 60°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 60°C.
MARKING QT00 on sensor rose.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES Consideration must be made on installation to the airgap arrangement. Consider balanced supplies or appropriate backflow protection at the inlets.
ADDITIONAL NOTES Opacity cannot be guaranteed on the premix control unit.

Extra Notes